



中国国家强制性产品认证证书



证书编号：2020322310002847

认证委托人名称：图尔克（天津）传感器有限公司
 认证委托人地址：天津经济技术开发区渤海路 34 号
 生产者名称：汉斯图尔克有限公司
 生产者地址：鲁尔区米尔海姆威茨雷本大街 7 号
 生产企业名称：维尔纳尔图尔克有限公司
 生产企业地址：Kirchloeber Weg 7, 58553 Halver, Germany

产品名称：总线网关模块
 系列、规格、型号：GEN-3G
 标准：GB 3836.1-2010、GB 3836.4-2010、GB 3836.8-2014

上述产品符合强制性产品认证实施规则 CNCA-C23-01:2019 的要求，特发此证。

发证日期：2020 年 10 月 15 日 有效期至：2025 年 10 月 14 日

首次发证日期：2020 年 10 月 15 日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站 www.cnca.gov.cn 查询



批准：



上海仪器仪表自控系统检验测试所有限公司



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION



CERTIFICATE NO: 2020322310002847

APPLICANT: Turck (Tianjin) Sensor Co., Ltd.
ADDRESS: No.34 Bohai Road, TEDA, Tianjin, P.R.China
MANUFACTURER: Hans Turck GmbH & Co. KG
ADDRESS: Witzlebenstr. 7, 45472 Mülheim an der Ruhr
FACTORY: Werner Turck GmbH & Co.,KG
ADDRESS: Kirchlocher Weg 7, 58553 Halver, Germany

PRODUCTNAME: Ethernet-Gateway
SERIES,SPECIFICATION,MODEL: GEN-3G
STANDARDS: GB 3836.1-2010、GB 3836.4-2010、GB 3836.8-2014

This is to certify that the above mentioned product(s)complies with the requirements of implementation rules for compulsory certification (REFNO. CNCA-C23-01:2019).

Valid from:October 15, 2020 **Valid until:** October 14, 2025

Date of original certification:October 15, 2020

The validity of this certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

This certificate is available through CNCA’s website: www.cnca.gov.cn



APPROVAL: 
 Xu JianPing



Shanghai Inspection and Testing Institute of Instruments and Automation Systems Co., Ltd.

<http://www.sitilas.com.cn>

Building 9,103 Cao Bao Road, Shanghai 200233,China

Tel: +86 21 64510844

S 0001878



中国国家强制性产品认证证书



证书编号: 2020322310002847

附 件

产品名称: 总线网关模块

型号规格: Ex nA ib [ib Gb] IIC T4 Gc

防爆标志: GEN-3G

电气参数: AC 电源回路, signal 回路, Address encoding 接口, Internet Gateway 接口, Service interface 接口, Reserve 接口需与 MT 系列 Module subrack 连接使用。

AC 电源回路:

连接件代号	插脚代号	电气参数 (最大值)
J1	15/16	U=20V AC f=300kHz~314kHz Ci=0 Li=0

Ethernet 接口 (RJ45 连接件 : ETH1, ETH2):

额定电压 U=3.3V

最大电压 Um=30V

批 准 :



上海仪器仪表自控系统检验测试所有限公司